

**Addendum No. 1
to the Bidding Documents**

**Ultraviolet Disinfection System Procurement
Town of Spencer, MA**

Issued: June 17th, 2021

Under the provisions of Article 7 of Section 00200, Instructions to Bidders, Bidders are informed that the Bidding Documents for the above-mentioned Project are modified, corrected, and/or supplemented as follows. Addendum No. 1 becomes part of the Bidding Documents and Contract Documents.

Acknowledge receipt of this addendum by inserting its number on Page 15, Section 6 Price Proposal Form, of the Request for Proposals. Failure to acknowledge receipt of the Addendum may subject the Bidder to disqualification.

Project Manual Changes

Item 1-1 Request for Proposals Advertisement

Delete the third paragraph in its entirety, and **replace** it with the following:

Proposals will be received at the Town of Spencer Utilities and Facilities, 3 Old Meadow Road, Spencer, Massachusetts, 01562 until 2:00 p.m. on Thursday, July 1, 2021. The Proposals will not be opened publicly.

Item 1-2 Section 1, Request for Proposals – General Information and Proposal Submittal Requirements

Under the first bullet, "Time and date of Receipt of Proposals and Rule for Award", **Delete** the first paragraph in its entirety, and **replace** it with the following:

Proposals shall be submitted to the Town of Spencer Board of Sewer Commissioners, Utilities and Facilities Office, 3 Old Meadow Rd. Spencer, MA 01562 at or before 2:00 p.m. on Thursday, July 1, 2021.

Item 1-3 Section 5, Request for Proposals – UV System Information Form

In Paragraph 5.1.A, Item No. 10, 11, and 12, **replace** the words "(Non-prorated)", with the word "(Prorated)".

Item 1-4 Section 00520 – Procurement Agreement

In Article 6, Paragraph 6.1 B., **replace** the words "Bidder may escalate" in the first sentence with the words "Bidder or Owner may choose to adjust".

Bidding Period Questions & Responses

The following responses/clarifications are based on questions raised during the bidding period.

1. Regarding the warranty: The UV System Information Form asks for non-prorated warranty life for the lamps, ballasts, sleeves, wipers and UV sensors, while Section 11262, Paragraph 1.7, allows for prorated warranties. Is the prorated warranty duration allowed to be used on the UV Information Form?

The Bidder shall list the prorated warranty duration for the lamps and ballasts on the UV System Information Form (Items No. 10, 11, and 12). See Item 1-3 above. Note that Items 13, 14, 15, and 16 on the UV System Information Form for wiper sleeves, UV intensity sensor, and UV transmittance monitor shall remain as "non-prorated" values.

END OF ADDENDUM NO. 1

\\tighebond.com\data\Data\Projects\S\S5097 Spencer WWTF\001 WWTF Upgrade Project\Bidding\UV Pre-Selection\Addenda\Addendum 1.docx